

Certificate of Compliance

This certificate is issued for the following equipment:

Open Water-Spray Nozzles for Fire Protection

Model	Nominal K-Factor (gpm/(psi) ^{1/2})	Nominal Spray Angle	NPT (in.)	Finishes
AFF	1.18, 1.66, 2.53, 2.85	145	1/2	Brass, Bronze, Stainless Steel, Titanium, and Cobalt, Copper, Nickel and Tantalum Based Alloys
AFF	3.35, 4.43, 5.69	145	3/4	Brass, Bronze, Stainless Steel, Titanium, and Cobalt, Copper, Nickel and Tantalum Based Alloys

Prepared for:

Bete Fog Nozzle Inc.
50 Greenfield St., Greenfield, MA 01301, USA

Manufacturing Location:

Bete Fog Nozzle Inc.
50 Greenfield St., Greenfield, MA 01301, USA

FM Approvals Class: 2025

FM Approval Standard: Class Number 2021/2025 (February 2010)

Approval Identification: PR471582

Approval Granted: 27 October 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062 USA

