



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Nominal Spray Angle (degrees)	Nominal Thread Size (in.)	Finishes
TF8NN	0.41	60	1/4	Brass
TF8FCN	0.41	90	1/4	Brass

Prepared for: Bete Fog Nozzle Inc., 50 Greenfield Street, Greenfield, MA 01301

Manufacturing Location: Bete Fog Nozzle Inc., 50 Greenfield Street, Greenfield, MA 01301

FM Approvals Class: 2025

FM Approval Standard: Class 2021/2025 (February 2010)

Approval Identification: 3044547

Approval Granted: March 20, 2012

**Certificate of Compliance Reissued: August 23, 2012**

This document supersedes the previously issued Certificate of Compliance. It was reissued to correct the NPT size designation from 3/8 in. to 1/4 in.

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'Richard B. Dunne', is written over a white rectangular background.

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

