



# Certificate of Compliance

This certificate is issued for the following equipment:

## Open Water-Spray Nozzles for Permanently Piped Systems

Model	Nominal K-Factor (gpm/(psi) <sup>1/2</sup> )	Nominal Spray Angle (Degrees)	NPT (in.)	Finishes
TF10	0.63	170	1/4	Brass <sup>a</sup> , Bronze, Copper Alloys

Notes: a - "Naval Brass" is not an FM Approved alloy for the TF10 nozzle

Prepared for: Bete Fog Nozzle Inc., 50 Greenfield Street, Greenfield, MA 01301, USA

Manufacturing Location: Bete Fog Nozzle Inc., 50 Greenfield Street, Greenfield, MA 01301, USA

FM Approvals Class: 2025

FM Approval Standard: Class Series 2021/2025 (February 2010)

Approval Identification: 3060448

Approval Granted: May 17, 2017

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



Member of the FM Global Group